

SCHEDULE OF WORK ITEMS AND ESTIMATED COSTS

FOR ROE USE ONLY	AMENDMENT NUMBER
	AMENDMENT DATE

1. COUNTY CODE/NAME:		2. DISTRICT CODE/NAME:		3. SITE CODE/NAME:		4. FACILITY CODE/NAME: Madison Elementary School	
ITEM I.D. (5)	ACTION I.D. (6)	PRIORITY CODE (7)	SPECIFICATION(S) (8)	QUANTITY (10)	LABOR CODE (11)	ESTIMATED COST (12)	ESTIMATED COMPLETION DATE (13)
1	b	b	Remove items from the top of the wall hung cabinets/shelving.	20 Each	1	\$ 0.00	Within 5 years
2	b	b	Remove items from corridor/stairwell.	5 Each	1	\$ 0.00	Within 1 year
3	f	b	Provide door closer.	2 Each	2	\$ 1,000.00	Within 5 years
4	f	a	Post emergency evacuation procedures.	1 Each	1	\$ 0.00	Within 1 year
5	b	b	Remove hold open device.	4 Each	1	\$ 0.00	Within 5 years
6	c	b	Adjust strike plate for proper operation.	1 Each	2	\$ 200.00	Within 5 years
7	f	b	Seal wall penetrations around piping with firestopping to maintain smoke rating.	1 Each	2	\$ 200.00	Within 5 years
8	b	a	Remove curtain.	1 Each	1	\$ 0.00	Within 1 year
9	e	a	Provide new sections of sidewalk flush with adjacent walk.	1 Each	2	\$ 1000.00	Within 1 year
10	f	a	Test the drinking water for the presence of lead.	1 Each	2	\$ 3,100.00	Within 5 years
11	f	b	Extend kiln exhaust directly to the outside to exhaust fumes. .	1 Each	2	\$ 3,000.00	Within 5 years
12	f	b	Adjust circuit breakers and space covers to conceal exposed wiring.	1 Each	2	\$ 250.00	Within 5 years

SCHEDULE OF WORK ITEMS AND ESTIMATED COSTS

FOR ROE USE ONLY	AMENDMENT NUMBER
	AMENDMENT DATE

1. COUNTY CODE/NAME:			2. DISTRICT CODE/NAME:			3. SITE CODE/NAME:			4. FACILITY CODE/NAME: Madison Elementary School		
ITEM I.D. (5)	ACTION I.D. (6)	PRIORITY CODE (7)	SPECIFICATION(S) (8)	QUANTITY (10)	LABOR CODE (11)	ESTIMATED COST (12)	ESTIMATED COMPLETION DATE (13)				
13	b	a	Relocate stored items to allow physical and visual access to fire alarm device.	1 Each	1	\$ 0.00	Within 1 year				
SUB-TOTAL:						\$ 8,750.00					
Contingencies				10%		\$ 875.00					
Arch./Engin. Fees				10%		\$ 875.00					
GRAND-TOTAL:						\$ 10,500.00					