

SCHEDULE OF WORK ITEMS AND ESTIMATED COSTS

FOR ROE USE ONLY	AMENDMENT NUMBER
	AMENDMENT DATE

1. COUNTY CODE/NAME:		2. DISTRICT CODE/NAME:		3. SITE CODE/NAME:		4. FACILITY CODE/NAME: Monroe Elementary School	
ITEM I.D. (5)	ACTION I.D. (6)	PRIORITY CODE (7)	SPECIFICATION(S) (8)	QUANTITY (10)	LABOR CODE (11)	ESTIMATED COST (12)	ESTIMATED COMPLETION DATE (13)
1	c	a	Adjust door hardware for proper operation.	1 Each	2	\$ 200.00	Within 1 year
2	f	a	Post emergency evacuation procedures.	16 Each	1	\$ 0.00	Within 1 year
3	b	b	Remove hold open device.	3 Each	1	\$ 0.00	Within 5 years
4	b	b	Remove items from stairwell.	2 Each	1	\$ 0.00	Within 5 years
5	b	b	Remove items from the top of the wall hung cabinets/shelving.	6 Each	1	\$ 0.00	Within 5 years
6	f	b	Infill roof deck flutes with fire safing.	1 Each	2	\$ 500.00	Within 5 years
7	b	b	Remove magnet from door strike plate.	1 Each	1	\$ 0.00	Within 5 years
8	c	b	Replace damaged caulk.	1 Each	2	\$ 200.00	Within 5 years
9	c	b	Adjust door hardware for proper operation.	1 Each	2	\$ 200.00	Within 5 years
10	b	b	Remove/relocate bench.	1 Each	1	\$ 0.00	Within 5 years
11	f	a	Remove one row of ceramic tile between door frame and provide transition strip between differing floor finish levels.	1 Each	2	\$ 500.00	Within 1 year
12	c	a	Replace cabinet door and handle.	1 Each	2	\$ 200.00	Within 1 year

SCHEDULE OF WORK ITEMS AND ESTIMATED COSTS

FOR ROE USE ONLY	AMENDMENT NUMBER
	AMENDMENT DATE

1. COUNTY CODE/NAME:		2. DISTRICT CODE/NAME:		3. SITE CODE/NAME:		4. FACILITY CODE/NAME: Monroe Elementary School		
ITEM I.D. (5)	ACTION I.D. (6)	PRIORITY CODE (7)	SPECIFICATION(S) (8)	QUANTITY (10)	LABOR CODE (11)	ESTIMATED COST (12)	ESTIMATED COMPLETION DATE (13)	
13	b	b	Remove items from corridor.	1 Each	1	\$ 0.00	Within 5 years	
14	c	b	Replace damaged face brick and tuckpoint masonry joints.	100 SF	2	\$ 2,000.00	Within 5 years	
15	f	b	Provide door closer.	2 Each	2	\$ 1,000.00	Within 5 years	
16	f	b	Provide new closer arm without hold-open function.	2 Each	2	\$ 400.00	Within 5 years	
17	f	a	Test the drinking water for the presence of lead.	1 Each	2	\$ 2,800.00	Within 1 year	
18	f	b	Provide junction box cover to conceal exposed wiring.	3 Each	2	\$ 300.00	Within 5 years	
19	f	b	Provide knock out cover to conceal exposed wiring.	5 Each	2	\$ 500.00	Within 5 years	
20	f	b	Conduct a survey to determine what loads this panel serves and provide an updated directory.	3 Each	2	\$ 6,000.00	Within 5 years	
21	c	b	Properly secure splice box cover to conceal exposed wiring.	1 Each	2	\$ 100.00	Within 5 years	
22	f	a	Provide emergency lighting in required space.	7 Each	2	\$ 3,500.00	Within 1 year	
23	f	a	Provide exit sign to indicate path of egress.	3 Each	2	\$ 1,500.00	Within 1 year	
24	f	a	Provide a fire alarm visual device in required space.	4 Each	2	\$ 2,000.00	Within 1 year	

SCHEDULE OF WORK ITEMS AND ESTIMATED COSTS

FOR ROE USE ONLY	AMENDMENT NUMBER
	AMENDMENT DATE

1. COUNTY CODE/NAME:			2. DISTRICT CODE/NAME:			3. SITE CODE/NAME:			4. FACILITY CODE/NAME: Monroe Elementary School		
ITEM I.D. (5)	ACTION I.D. (6)	PRIORITY CODE (7)	SPECIFICATION(S) (8)	QUANTITY (10)	LABOR CODE (11)	ESTIMATED COST (12)	ESTIMATED COMPLETION DATE (13)				
25	c	b	Provide light bulb in fixture.	2 Each	2	\$ 200.00	Within 5 years				
26	c	b	Repair existing light fixture.	3 Each	2	\$ 600.00	Within 5 years				
27	b	b	Relocate stored items to provide 36" clearance in front of electrical equipment in this space.	12 Each	1	\$ 0.00	Within 5 years				
28	f	a	Provide light fixture above exterior exit door to provide lighting for path of egress.	4 Each	2	\$ 800.00	Within 1 year				
SUB-TOTAL:						\$ 23,500.00					
				Contingencies 10%		\$ 2,350.00					
				Arch./Engin. Fees 10%		\$ 2,350.00					
GRAND-TOTAL:						\$ 28,200.00					